



Godiva Ltd
Charles Street
Warwick, Warwickshire
CV34 5LR
England



Class 1
Godiva Ltd
Hale Products

DECLARATION OF COMPLIANCE

We confirm that pump type P1_ 3010 Complies with the requirements of EN1028-1: 2002, and has been tested in accordance with EN 1028-2:2002, and conforms to the classification:

Fire-fighting centrifugal pump EN1028-1 – FPN 10-3000.

Nominal Speed n_N :	3210 RPM
Nominal Pressure p_N :	10.0 Bar
Nominal Delivery rate:	3000 L/Min
Suction Height $H_{s\ geo N}$:	3.0 m
Priming Speed n_s :	2500 RPM
Priming Time t:	10 seconds.

Simon Tudor

Director of Engineering
Godiva Ltd

An IDEX Fire & Safety Business

phone +44 (0)1926 623600 fax +44 (0)1926 623666 e-mail godiva@idexcorp.com www.godiva.co.uk

Incorporated in England registered in England number 11943. Registered office 100 New Bridge Street London EC4V 6JA VAT No. GB200 4622 27.

Barclays Bank plc £sterling: Code (20-00-00) a/c 40745693. Swift: BARCGB22. US\$ Code: (20-00-00) a/c 79707755. EUR: Code (20-00-00) a/c 85344188