


DECLARATION OF COMPLIANCE

We confirm that pump type P1_ 6010 Complies with the requirements of EN1028-1: 2002, and has been tested in accordance with EN 1028-2:2002, and conforms to the classification:

Fire-fighting centrifugal pump EN1028-1 – FPN 10-6000.

Nominal Speed n_N :	3300 RPM
Nominal Pressure p_N :	10.0 Bar
Nominal Delivery rate:	6000 L/Min
Suction Height $H_{s_{geoN}}$:	3.0 m
Priming Speed n_s :	2500 RPM
Priming Time t:	17 seconds.

Simon Tudor



Director of Engineering
Godiva Ltd